

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7258-1130:204 Page 1 of 1

CATEGORY: Combination Ionization/Photoelectric Smoke Detector

LISTEE: Honeywell Inc., 1500 West Dundee Road, Arlington Heights, IL 60004
Contact: Bob Hodgson (847) 797-4403

DESIGN: Model TC840A1001, addressable combination ionization and photoelectric smoke detector. Unit also employs a 135° F heat sensor which intended for use only as a supplemental device to the smoke detector to increase the sensitivity of the smoke detector during a fire.

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, air velocity rating and UL label.

APPROVAL: Listed as combination ionization/photoelectric, addressable type smoke detector for use with separately listed compatible detector base and fire alarm control units.

NOTE: Integral heat sensor is NOT approved for use as a heat detector.

05-11-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 13, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager